



May 2, 2019

New Bedford Conservation Commission
New Bedford City Hall
133 Williams Street
New Bedford, MA 02740

**RE: Detention Pond As-Built Report
100 Duchaine Boulevard – New Bedford, MA**

Dear Commission Members:

On behalf of the property owner and applicant, MIH1, LLC, please find an As-Built Plan and HydroCAD© calculations enclosed with this letter detailing the storage capacity of the existing detention basins. The following table is a representation of the proposed conditions vs. existing conditions, specifically the storage volumes of the stormwater management basin provided on site at the above referenced project.

Table 1 - Comparison of Proposed Vs. As-Built Conditions of Detention Basins	
Basin	DB
	Volume (C.F.)
Proposed	12,284
Existing	19,474

We trust the attachments noted above and included herewith will provide the necessary documentation to address the special conditions within the Order of Conditions issued on March 19, 2016. If you should have any questions, please feel free to contact us.

Very truly yours,

FARLAND CORP., INC.

Jack Tabares
Project Manager