

Sarah Porter

From: Sarah Porter
Sent: Friday, March 14, 2014 3:27 PM
To: rrheaume@primeengineering.org; 'Courtney Cohen'
Cc: 'Scott Turner'; Jennifer Johnson
Subject: erosion control plan

Rich, the erosion control plan shows the erosion controls associated with grading for the swale near Swallow St. to intersect the proposed grading lines at the outlet for the swale near to the 25' No Disturb Zone. The proposed grades are within 5' of the wetland boundary which is a significant encroachment into the 25' no disturb zone as noted by Nitsch engineering. It appears that you could pull back the grading to respect the 25' no disturb zone. Please pull back the outlet grading so that it terminates at the 25' No Disturb Zone in this vicinity. As currently proposed you have grading within 5' of the wetland boundary without any erosion controls.

Thank you
Sarah Porter