



March 13, 2014

JN 1931-01-01

New Bedford Conservation Commission  
133 William Street  
New Bedford, MA 02740

**RE: CARDINAL PLACE SUBDIVISION**

Dear Commission Members,

Enclosed is a set of plans that have been revised in response to the comments in the March 14, 2014 letter from Nitsch Engineering to you. Our responses are as follows:

1. The sidewalks have been deleted;
2. The extremely high elevation of the drainline in Swallow Street makes it impossible to install a Stormceptor or any other BMP in this existing catch basin. The proposed design, however, will greatly reduce the volume and rate of flow to Sassaquin Pond from this very small area;
3. We agree;
4. The grading in the 25 foot no disturb zone has been eliminated.

We now have made all revisions requested and look forward to your approval.

Sincerely,  
**PRIME ENGINEERING, INC.**



Richard J. Rheume, P.E., LSP  
Chief Engineer

enc.