



ENVIRONMENTAL STEWARDSHIP DEPARTMENT/
NEW BEDFORD CONSERVATION COMMISSION

CITY OF NEW BEDFORD
JONATHAN F. MITCHELL, MAYOR

Memorandum

To: Christian Farland, PE
Thompson Farland, Inc

April 3, 2014

From: Sarah Porter
Conservation Agent

Re: SE49-0699
Downey Street
Proposed airplane hangars and parking area.

The following comments are provided on the Notice of Intent, Stormwater Management Report and Plans:

1. Please add the intermittent stream which discharges from a headwall between flags 8 and 9 and runs southerly parallel to the wetland boundary between flags 7 and 8.
2. The NOI, plan notes and stormwater checklist reference an erosion and sedimentation control plan but none is provided. Please provide one.
3. Is there a net increase in impervious area from the paving of the grassy areas?
4. No construction period pollution prevention plan has been included.
5. The stormwater report references groundwater recharge and a reference to Table 3 which has not been provided.
6. It is recommended that the Long term pollution prevention plan state that the dumping of snow in the Bordering Vegetated Wetlands and stockpiling it on top of catch basins or the water quality inlet is prohibited.

Cc: file, Conservation Commissioners