



CITY OF NEW BEDFORD
ADDENDUM #2

The City of New Bedford issues the following Addendum #2 for

IFB #16450135
Turners Pond Dam Vegetation Maintenance
November 13, 2015

This addendum is issued to provide bidders with Questions and Answers for the above named IFB

Q1: Is it clear cutting or selective removal of trees along the earthen dam embankment on the north side of the road?

A1: This is clear cutting of trees cut down flush to ground and cut surfaces to be sealed with a waterproof sealant

Q2. On the south side of the road along the stream is it 20' up of cutting along the stream or just 20' down from the toe of the dam?

A2: The cutting is 20' of the downstream toe of the dam, flush to ground surface

Q3. Is it possible to modify the plan to bubble out (in red) the areas in approximate scale that the work will take place?

A3: There is no deviation from the Conservation Commission or the scope of work by CDM Smith