

**City of New Bedford
New Bedford Public Schools
New Bedford, Massachusetts**

Addendum #2

**Change to the Invitation for Bids
for
Inspection, Testing and Preventative Maintenance of Fire Alarm and Sprinkler Systems
for
New Bedford Public Schools**

Addendum Date: June 8, 2015

This Addendum modifies and amends sections in the Inspection, Testing and Preventative Maintenance of Fire Alarm and Sprinkler Systems Invitation for Bids specification dated May 28, 2015; and is hereby binding as though inserted in its entirety in the initial specification.

ITEM A: Questions by Vendor

1. There are no Tamper Switches or Flow switches listed for the sprinkler systems at the New Bedford HS.

Answer: **40 Tamper Switches and 30 Flow Switches**

Insert: Exhibit A will be updated to reflect this change.

2. The number of Audio Visual devices is not quantified at NBHS

Answer: **104 Audio Visual devices**

Insert: Exhibit A will be updated to reflect this change.

ITEM B: Pre-Bid Meeting Notes and Changes

1. See the attached sign in log

2. Section **IV. Scope of Work**

16. STORAGE OF SPARE PARTS - Customer shall provide the vendor with a secure area for the storage of spare parts. The vendor may maintain at the site the following parts in stock. The storage of spare parts in this section is not required, optional.

PART	QUANTITY
Smoke Detector	2
Heat Detector	2
Pull Stations	2
Fuses	2

Insert: 16. STORAGE OF SPARE PARTS will be updated to reflect this change.

3. Section **IV. Scope of Work**

17. FIRE ALARM EQUIPMENT TEST - Vendor shall inspect and test 100% of the Fire Alarm Equipment at least one time per year. Quarterly Inspections may be performed on: *Mondays through Fridays from 7:00AM to 3:00PM and at several locations on the second shift, during vacation breaks and during summer break.* Each inspection shall include all peripheral devices, i.e. pull stations, heat detectors, smoke detectors, duct detectors, audiovisuals and auxiliary function. Any necessary adjustments or repairs found to be needed during the inspections are to be quoted as additional cost items. The fire alarm systems at each school must be 100% tested no later than May 31st of the Fiscal Year (May 31, 2016).

Insert: 17. FIRE ALARM EQUIPMENT TEST will be updated to reflect this change.

4. Add **ELEVATOR LOCATIONS**

Insert: EXHIBIT B - LIST OF ELEVATOR LOCATIONS

NOTE: Please confirm this addendum on the submitted BID FORM.

Exhibit B LIST OF ELEVATOR LOCATIONS

New Bedford Public Schools

May 2015

School	Address	SF	AGE
New Bedford High School (2)	230 Hathaway Boulevard	563,000	1972
Middle Schools			
Keith Middle School (2)	225 Hathaway Boulevard	231,510	2006
Normandin Middle School (2)	81 Felton Street	217,000	2003
Roosevelt Middle School (2)	119 Fredrick Street	215,000	2001
Elementary Schools			
Sgt Wm H Carney Acad Elementary School	247 Elm Street	124,075	1973
Hayden/McFadden Elementary School	361 Cedar Grove Street	80,863	1975
Alfred J Gomes Elementary School	286 South Second Street	137,345	1973
Abraham Lincoln Elementary School	445 Ashley Boulevard	93,833	2010
Casmir Pulaski Elementary School	1097 Braley Road	130,322	1974
Administration Building			
Paul Rodrigues Administration Building	455 County Street	183,450	1934
Adult/Teen Education			
Trinity Day Academy	181 Hillman Street	65,000	1936
McCoy			
McCoy	181 Hillman Street	65,000	1936